

ORLANDO srl



**MOTOR PUMP DRY RUNNING CONTROL
THERMOSTAT**

The TE is made up of a thermic sensor which controls the body pump temperature. The normal working temperature is set at 45°C and passing this value activates a protection signalled by a led.

The electrical contact is a 16 (4) A250V a.c. switch that has to be **re-set manually** after being activated.



Cod: MT TE:



